

NON-FULLY DEVELOPED FLOW IN AN ELBOW PIPE UNDER THE INDIAN NPP FLOW CONDITIONS

Theegala Divya, Hari Ponnama Rani
NIT Warangal
divya_2087@yahoo.com, hprani@nitw.ac.in

Abstract

The objective of this paper is to examine the last step of the mechanistic model of wall thinning degradation mechanism i.e., convective mass transfer in feeder pipes under different environments of piping of nuclear power plants (NPP). In the present study, the flow and mass transfer of demineralised water in carbon steel double elbow was simulated under Indian NPP feeder water system conditions. The analysis carried out in this study based on the position of the first elbow i.e., the first elbow positioned at the non fully developed flow in the upstream region of first elbow as the piping system in NPP contains such type of construction of piping. For this analysis the upstream horizontal limb of the double elbow considered to be of different lengths 0.09m, 0.11m, 0.13m and 0.15m. MTC is the most important parameter to predict the highly susceptible FAC locations. For the MTC analysis, the Chilton - Colburn analogy in terms of wall shear stress used. The reported results are useful for developing the targeted inspection plans in predicting the vulnerable FAC locations.

References

1. S. ROYCHOWDHURY AND V. KAIN AND A. MATCHESWALA AND A. BHANDAKKAR. Sigma phase induced embrittlement in titanium containing austenitic stainless steel tie-bars in a condenser. *Engineering Failure Analysis*, 25, 123-132 (2012).
2. J.L. SINGH AND UMESH KUMAR AND N. KUMAWAT AND SUNIL KUMAR AND V. KAIN AND S. ANANTHARAMAN AND A.K. SINHA . Flow accelerated corrosion of carbon steel feeder pipes from Pressurized Heavy Water Reactors. *Journal of Nuclear Materials*, 429, 226 – 232(2012).
3. H.P.RANI AND T. DIVYA AND R. R.SAHAYA AND VIVEKANAND KAIN AND D.K. BARUA. CFD study of flow accelerated corrosion in 3D elbows. *Annals of Nuclear energy*, 69, 344-351(2014).